



Certificate of Compliance

Certificate: 80021505

Master Contract: 266494

Project: 80035967

Date Issued: 2020-03-25

Issued to: Longi Green Energy Technology Co., Ltd.
No. 388, Middle Hangtian Road
Chang'an District, Xi'an, Shaanxi, 710100
China

Attention: Fei Zhuang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: Tom Yang
Tom Yang

PRODUCTS

CLASS - C531110 - POWER SUPPLIES-Photovoltaic Modules and Panels

CLASS - C531190 - POWER SUPPLIES-Photovoltaic Modules and Panels - Certified to US Standards

Bifacial dual glass photovoltaic modules with maximum system voltage of 1500 V dc, Safety Class II PV modules.

LR6-72BP-xxxM, xxx=350 to 380, in steps of 5W,

LR6-72PD-xxxM, xxx= 345 to 370, in steps of 5W,

LR6-72DG-xxxM, xxx= 330 to 360, in steps of 5W,

LR6-72HBD-xxxM, xxx= 360 to 385, in steps of 5W,

LR6-72HIBD-xxxM, xxx= 360 to 385, in steps of 5W,

LR6-72OPD-xxxM, xxx= 380 to 405, in steps of 5W,

LR6-72HPD-xxxM, xxx= 360 to 385, in steps of 5W,

LR6-72MBD-xxxM, xxx= 360 to 380, in steps of 5W,

LR6-72MPD-xxxM, xxx= 360 to 380, in steps of 5W,

LR4-72HBD-xxxM (xxx= 415 to 455), in steps of 5W,

LR4-72HIBD-xxxM (xxx= 415 to 435), in steps of 5W,

LR6-60BP-xxxM, xxx=290 to 315, in steps of 5W,

LR6-60PD-xxxM, xxx=285 to 305, in steps of 5W,

LR6-60DG-xxxM, xxx=275 to 300, in steps of 5W,

LR6-60HBD-xxxM, xxx= 300 to 320, in steps of 5W,



Certificate: 80021505
Project: 80035967

Master Contract: 266494
Date Issued: 2020-03-25

LR6-60HIBD-xxxM, xxx= 300 to 320, in steps of 5W,
LR6-60OPD-xxxM, xxx= 315 to 335, in steps of 5W,
LR6-60HPD-xxxM, xxx= 300 to 320, in steps of 5W,
LR6-60MBD-xxxM, xxx= 300 to 320, in steps of 5W,
LR6-60MPD-xxxM, xxx= 300 to 320, in steps of 5W,
LR4-60HBD-xxxM (xxx= 345 to 380), in steps of 5W,
LR4-60HIBD-xxxM (xxx= 345 to 365), in steps of 5W,
LR6-78HBD-xxxM, xxx= 390 to 420, in steps of 5W,
LR6-78OPD-xxxM, xxx= 410 to 435, in steps of 5W,

Note:

1. All electrical data are shown as relative to standard test conditions (STC) (1 000 W/m², (25 ± 2) °C, AM 1,5 according to IEC 60904-3).
2. Manufacturer's stated tolerance is ±3% for Voc and Pm, and Isc.
3. Rated electrical characteristics are only reflected the front side performance, regardless of the back side.
4. All modules model with suffix 'BP' after '72' or '60', are bifacial modules
5. All modules model with suffix 'PD' after '72' or '60', are modules with PERC cells.
6. All modules model with suffix 'DG' after '72' or '60', are modules with common one side mono-si cells.
7. All modules model with suffix 'HBD' after '72' or '60' or '78', are modules with bifacial mono-si half-cut cells.
8. All modules model with suffix 'OPD' after '72' or '60' or '78', are modules with bifacial mono-si shingled cells (1/6 cut).
9. All modules model with suffix 'HPD' after '72' or '60', are modules with monofacial mono-si half-cut cells.
10. All modules model with suffix 'MBD' after '72' or '60', are modules with bifacial mono-si MBB cells.
11. All modules model with suffix 'MPD' after '72' or '60', are modules with monofacial mono-si MBB cells.
12. All modules model with suffix 'HIBD' after '72' or '60', are modules with bifacial mono-si 6BB half-cut cells.
13. LR6 is for models with 156mm cells, and LR4 is for models with 166mm cells.
14. For details related to rating, size, configuration, etc. reference should be made to CSA Certification Record or the descriptive report.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61730-1:19	Photovoltaic (PV) module safety qualification - Part 1: Requirements for construction
CAN/CSA-C22.2 No. 61730-2:19	Photovoltaic (PV) module safety qualification - Part 2: Requirements for testing
UL 61730-1:2017	Photovoltaic (PV) Module Safety Qualification - Part 1: Requirements for Construction
UL 61730-2:2017	Photovoltaic (PV) Module Safety Qualification - Part 2: Requirements for Testing



Supplement to Certificate of Compliance

Certificate: 80021505

Master Contract: 266494

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80035967	2020-03-25	Update report to add alternate cells interconnectors, and alternate output wiring compartments PV-LR02A, PV-LR03A, PV-LR04A.
80027423	2020-03-25	Update report to add alternate cells M6B9B and M6E9B, interconnectors, and alternate module sizes for models with 9bb M6 cells.
80034138	2020-02-27	Update report to add models LR4-72HBD-xxxM and LR4-60HBD-xxxM for new bifacial cell type M6B6B manufactured by LONGi.
80023865	2020-02-21	Update report to add alternate cell M2D5B.
80023861	2020-02-19	Update report to add new model series LR6-72HIBD-xxxM, LR6-60HIBD-xxxM, with cell M2D6B, and LR4-60HIBD-xxxM, LR4-72HIBD-xxxM, with cell M6D6B.
80030667	2020-01-10	Update report to add combinations of materials and new model series, as a reference of Test Report No. 704061700509-09 by TÜV SÜD Certification and Testing (China) Co., Ltd and previous CSA projects.
80021505	2019-11-28	Original certification